

The Fort Bend Subsidence District Rules are amended as follows:

1) Rule 8.2 is amended to read as follows:

RULE 8.2 WATER METER EXCEPTIONS

- a. Windmills are excepted from Rule 8.1.
- ~~a.~~b. Wells five inches nominal or less in inside casing diameter where there is a reasonable basis to determine that pumpage will not exceed one million gallons per year, the well is not connected with any other well or aggregate system and the groundwater will not be used for any outdoor use or filling ponds are excepted from Rule 8.1.
- ~~b.~~c. Alternative water supply connections that are metered pursuant to a retail or wholesale agreement, or a rate order duly adopted by a regional water supplier, that requires payment based on the total amount of water supplied through the meter, are excepted from Rule 8.1.